

Putnam Central School
 126 County Rt 2
 Putnam Station ,NY 12861

Printed On : 2/3/2023 Page 1 of 1
 Sample ID: BE00758
 Date Received: 01/31/2023
 Time Received: 12:48
 Date Finalized: 2/3/2023
 PO Number:
 Your Ref:

Customer: Putnam Central School
 Owner: Putnam Central School
 Sample Loc: 126 County Rt2
 Sample Pt: Kitchen CWT

Collect Date: 01/30/2023
 Collect Time: 05:00
 Collected by: JIM FORBES
 Receipt Temp: 3.1 C on ice chilling

Water Source: Drilled Well
 Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
 Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	2/3/2023

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- blank
- C(+/-) CCV outside acceptance limits received
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- H Hold time exceeded
- B Analyte detected in
- G Incorrect bottle

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Putnam Central School

126 County Rt 2

Putnam Station ,NY 12861

Printed On : 2/3/2023

Page 1 of 1

Sample ID: BE00759

Date Received: 01/31/2023

Time Received: 12:48

Date Finalized: 2/3/2023

PO Number:

Your Ref:

Customer: Putnam Central School

Owner: Putnam Central School

Sample Loc: 126 County Rt2

Sample Pt: Water Fountain

Collect Date: 01/30/2023

Collect Time: 06:45

Collected by: JIM FORBES

Receipt Temp: 3.1 C on ice chilling

Water Source: Drilled Well

Chlorinated: Yes Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	2/3/2023

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- blank
- C(+/-) CCV outside acceptance limits received
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- H Hold time exceeded
- B Analyte detected in
- G Incorrect bottle

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Putnam Central School
126 County Rt 2
Putnam Station ,NY 12861

Printed On : 2/3/2023 Page 1 of 1
Sample ID: BE00760
Date Received: 01/31/2023
Time Received: 12:48
Date Finalized: 2/3/2023
PO Number:
Your Ref:

Customer: Putnam Central School **Collect Date:** 01/30/2023
Owner: Putnam Central School **Collect Time:** 05:51
Sample Loc: 126 County Rt2 **Collected by:** JIM FORBES
Sample Pt: Bsmt Hall Sink **Receipt Temp:** 3.1 C on ice chilling
Water Source: Drilled Well **Potable:** Yes
Chlorinated: Yes **Field Residual Chlorine:** **Grab/Comp:** Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	2/3/2023

Qualifiers Key:

X Exceeds maximum contamination limit R Duplication outside acceptance limits H Hold time exceeded
 T Temperature outside specifications A Sample contained air bubble or headspace B Analyte detected in
 blank
 C(+/-) CCV outside acceptance limits Z Analysis is not state-certified G Incorrect bottle
 received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Putnam Central School

126 County Rt 2

Putnam Station ,NY 12861

Printed On : 2/3/2023

Page 1 of 1

Sample ID: BE00761

Date Received: 01/31/2023

Time Received: 12:48

Date Finalized: 2/3/2023

PO Number:

Your Ref:

Customer: Putnam Central School

Owner: Putnam Central School

Sample Loc: 126 County Rt2

Sample Pt: Boys Bathroom 1 CWT

Collect Date: 01/30/2023

Collect Time: 05:41

Collected by: JIM FORBES

Receipt Temp: 3.1 C on ice chilling

Water Source: Drilled Well

Chlorinated: Yes **Field Residual Chlorine:**

Potable: Yes

Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	2/3/2023

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- blank
- C(+/-) CCV outside acceptance limits received
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- H Hold time exceeded
- B Analyte detected in
- G Incorrect bottle

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Putnam Central School
 126 County Rt 2
 Putnam Station ,NY 12861

Printed On : 2/3/2023 Page 1 of 1
 Sample ID: BE00762
 Date Received: 01/31/2023
 Time Received: 12:48
 Date Finalized: 2/3/2023
 PO Number:
 Your Ref:

Customer: Putnam Central School
 Owner: Putnam Central School
 Sample Loc: 126 County Rt2
 Sample Pt: Boys Bathroom 2 CWT

Collect Date: 01/30/2023
 Collect Time: 05:38
 Collected by: JIM FORBES
 Receipt Temp: 3.1 C on ice chilling

Water Source: Drilled Well
 Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
 Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	2/3/2023

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- blank
- C(+/-) CCV outside acceptance limits received
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- H Hold time exceeded
- B Analyte detected in
- G Incorrect bottle

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Putnam Central School
 126 County Rt 2
 Putnam Station ,NY 12861

Printed On : 2/3/2023 Page 1 of 1
Sample ID: BE00763
Date Received: 01/31/2023
Time Received: 12:48
Date Finalized: 2/3/2023
PO Number:
Your Ref:

Customer: Putnam Central School
Owner: Putnam Central School
Sample Loc: 126 County Rt2
Sample Pt: Pre K and K CWT

Collect Date: 01/30/2023
Collect Time: 05:30
Collected by: JIM FORBES
Receipt Temp: 3.1 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	2/3/2023

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- blank
- C(+/-) CCV outside acceptance limits received
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- H Hold time exceeded
- B Analyte detected in
- G Incorrect bottle

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Putnam Central School
 126 County Rt 2
 Putnam Station ,NY 12861

Printed On : 2/3/2023 Page 1 of 1
 Sample ID: BE00764
 Date Received: 01/31/2023
 Time Received: 12:48
 Date Finalized: 2/3/2023
 PO Number:
 Your Ref:

Customer: Putnam Central School Collect Date: 01/30/2023
 Owner: Putnam Central School Collect Time: 05:45
 Sample Loc: 126 County Rt2 Collected by: JIM FORBES
 Sample Pt: Girls Bathroom CWT Receipt Temp: 3.1 C on ice chilling
 Water Source: Drilled Well Potable: Yes
 Chlorinated: Yes Field Residual Chlorine: Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	2/3/2023

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- blank
- C(+/-) CCV outside acceptance limits received
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- H Hold time exceeded
- B Analyte detected in
- G Incorrect bottle

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.

Reviewed by Brian Collins
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.