

Laboratory Report

CLIENT: Champlain Valley Edu Services
 PROJECT: Lead in School Taps, Putnam CS

WORK ORDER: **1609-21853**
 DATE RECEIVED: 9/26/16

001	Site: Pre K&K (CWT)	Stagnant:	6.33 Hrs	Date Sampled:	9/21/16	Time:	20:20
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0011	mg/L	SM 3113B-04	10/11/16	W RJL	A	
002	Site: Boys BTHROOM Sink 1 (CWT)	Stagnant:	8.37 Hrs	Date Sampled:	9/21/16	Time:	22:22
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/11/16	W RJL	A	
003	Site: Boys BTHROOM Sink 2 (CWT)	Stagnant:	8.40 Hrs	Date Sampled:	9/21/16	Time:	22:24
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0015	mg/L	SM 3113B-04	10/11/16	W RJL	A	
004	Site: Girls BTHROOM (CWT)	Stagnant:	8.45 Hrs	Date Sampled:	9/21/16	Time:	22:27
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0087	mg/L	SM 3113B-04	10/11/16	W RJL	A	
005	Site: Water Fountain	Stagnant:	8.48 Hrs	Date Sampled:	9/21/16	Time:	22:29
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/11/16	W RJL	A	
006	Site: BSMT Hall Sink (CWT)	Stagnant:	8.58 Hrs	Date Sampled:	9/21/16	Time:	22:35
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0010	mg/L	SM 3113B-04	10/11/16	W RJL	A	
007	Site: Kitchen Sink (CWT)	Stagnant:	8.62 Hrs	Date Sampled:	9/21/16	Time:	22:37
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0011	mg/L	SM 3113B-04	10/11/16	W RJL	A	

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.